

Moab City
217 E. Center Street
Moab, UT 84532

PRESTO STD
U.S. POSTAGE
PAID
Moab, UT 84532
Permit #39

POSTAL PATRON
MOAB, UT 84532

MOAB CITY Water Quality Report 2014

We at Moab City work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

First in the Nation
Community in the Nation



Water Quality Report

This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources have been determined to be from ground water.

Protecting Water Sources

The Drinking Water Source Protection Plan for Moab is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources have been determined to have a low level of susceptibility from potential contamination. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

Cross Connection Control Program

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper jipping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unapproved garden hose lying in the puddle next to the driveway is a cross connection. The unapproved lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

Contaminants

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or man made. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.



Moab City is pleased to report that our drinking water meets federal and state requirements. Moab routinely monitors for constituents in our drinking water in accordance with the federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2014. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

TEST RESULTS

Contaminant	Violation Y/N	Level Detected (MCL/ow-High)	Unit Meas.	MCLG	MCL	Date Sampled	Likely Source of Contamination
INORGANIC CONTAMINANTS							
Chromium	N	2	ppb	100	100	2008	Discharge from steel and pulp mills; erosion of natural deposits
Copper a. 90% results b. # of sites that exceeded the AL	N	a. 54200 b. 0	ppb	1300000	AL=1300000	2013	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	134-155	ppb	4000	4000	2008	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceeded the AL	N	a. 1230 b. 0	ppb	0	AL=15000	2013	Corrosion of household plumbing systems; erosion of natural deposits
Nitrate (as Nitrogen)	N	262	ppb	10000	10000	2013	Runoff from fertilizer use; leaching from septic tanks; sewerage; erosion of natural deposits
Selenium	N	1	ppb	50	50	2008	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	12-13	ppm	None set by EPA	None set by EPA	2008	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	31-62	ppm	1000	1000	2008	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved Solids)	N	152-214	ppm	2000	2000	2008	Erosion of natural deposits
DISINFECTION BY-PRODUCTS							
Chlorine	N	300	ppb	4000	4000	2014	Water additive used to control microbes

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Nitrate Chemical Monitoring (Code 03) (10-10) - We periodically monitor for Nitrate in the water supply to meet all regulatory requirements. In 2014 we failed to take the required samples. Nitrate testing ensures that the public is provided with safe drinking water. This violation does not necessarily pose a health risk. In previous years, (tested) Nitrate samples revealed that our water was within the required state limits. In this current year the samples have been taken and show that we are still meeting drinking water standards.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

MCL/ow - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or Milligram per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanogram per liter (nanogram/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Date - Because of required sampling time frames (i.e., yearly, 3 years, 4 years and 6 years, sampling dates may seem out-of-date).

Lead Levels

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Moab City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Please Attend Our Meetings

We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held 2nd and 4th Tuesday, 7:00pm at the City Hall, 217 East Center Street, Moab, Utah.

Do You Have Questions?

If you have any questions about this report or concerning your water utility, please contact Levi Jones at 435-259-7485. We want our valued customers to be informed about their water utility.

Moab City

217 E. Center Street
Moab, UT 84532

P 435-259-5121
F 435-259-4135

visit our website at:
www.moabcity.org

First EPA Green Power
Contaminant in the Water

First in the Nation

